Nash County Environmental Health

On-Site Wastewater Permit
120 W. Washington Street, Nashville, NC 27856
252-459-9829

Nash County
North Carolina

Permit Number: E-25-118 Parcel ID: 033207 TOWNSHIP: North Whitakers
PIN: 382500572952 Owner: Green Farms Inc.
Applicant: Doug Peterson
Company: Carolina Rural Homes LLC

Subdivision: Sect: Ph: Lot: ,
Address of Property: 9729 FIRE TOWER FARM RD WHITAKERS, NC 27891
Design Specifications: New Subsurface Disposal System Non-Residential Use:
Design Flow: 360 LTAR: .225-.25 Trench Length:
Size Tank: 1000 Pump Tank: Grease Trap:
Type System: Max Trench Depth: Bedrooms: 3
Max Occupants: 6
Additional Inspections Required: Installer:

This permit is valid for 5 years from Improvement Permit date.

Conditions: Do not drive, park, build, pave or concrete over any part of the system or repair. Site alterations or variations from the site plan may void permit and/or make the site unsuitable. System must be installed as permitted. Install drain lines on contour. Install drain field in dry conditions. If a pump system is required, a pressure manifold shall be used. **THE CONSTRUCTION AUTHORIZATION (CA) HAS NOT BEEN SIGNED. A building permit shall not be issued until the CA is signed. In order for the CA to be signed the following conditions shall be met. The property shall be cleared, property lines shall be reflagged, house location shall be flagged, and a return trip to the lot will be needed (for system design, LTAR, and trench depth). Call the Environmental Health with any further questions. Minimum soil disturb in system area is required.**

Improvement Permit: **April 3, 2025** Authorized State Agent (Digitally Signed By): **Eric Griffin REHS**
Construction Authorization: Authorized State Agent (Digitally Signed By):
Operation Permit: Authorized State Agent (Digitally Signed By):